# TEST AND DRAIN VALVE MODELS HD90 & HD91



## **TECHNICAL DATA**

MODEL	HD90 & HD91
SIZE	1", 1-¼", 1-½" , 2" 1" size available in HD90 only
WORKING PRESSURE	300 PSI
CONNECTION	HD90 – NPT/BSPT HD91 – Grooved
K-FACTOR	5.6 (standard) 4.2 (optional)
APPROVAL	UL Listed & FM Approved
ORDERING INFORMATION	Model Number and Size



Test and drain valves are compact 3-position ball valves with drain orifice having K-factor 5.6 or 4.2 (optional) and a sight glass. 3-positions consists of OFF-TEST and DRAIN. Test and drain valves provide test as well as express drain functions in wet sprinkler systems. Model HD90 has NPT end connection while HD91 comes with grooved end connection ends. HD90 & HD91 come in Brass ASTM B584 material of construction. These have integral tamper resistant sight glass.

PART NAME	MATERIAL	QTY
BODY	BRASS ASTM B584	1
END PIECE	BRASS ASTM B584	1
BALL	BRASS	1
SEAT	TFM	2




## **VALVE OPERATION**

#### To Test:

- Turn valve handle counter-clockwise from OFF to TEST.
- 2. After test is completed, Return handle to OFF.

# To Drain:

- Turn valve handle counter-clockwise from OFF to DRAIN.
- 2. After test is completed, Return handle to OFF.





### LIMITED WARRANTY

HD FIRE PROTECT PVT. LTD. hereby referred to as HD FIRE warrants to the original purchaser of the fire protection products manufactured by HD FIRE and to any other person to whom such equipment is transferred, that such products will be free from defect in material and workmanship under normal use and care, for two (2) years from the date of shipment by HD FIRE. Products or Components supplied or used by HD FIRE, but manufactured by others, are warranted only to the extent of the manufacturer's warranty. No warranty is given for product or components which have been subject to misuse, improper installation, corrosion, unauthorized repair, alteration or un-maintained. HD FIRE shall not be responsible for system design errors or improper installation or inaccurate or incomplete information supplied by buyer or buyer's representatives. HD FIRE will repair or replace defective material free of charge, which is returned to our factory, transportation charge prepaid, provided after our inspection the material is found to have been defective at the time of initial shipment from our works. HD FIRE shall not be liable for any incidental or consequential loss, damage or expense arising directly or indirectly from the use of the product including damages for injury to person, damages to property and penalties resulting from any products and components manufactured by HD FIRE. HD FIRE shall not be liable for any damages or labour charges or expense in making repair or adjustment to the product. HD FIRE shall not be liable for any damages or charges sustained in the adaptation or use of its engineering data & services. In no event shall HD Fire's product liability exceed an amount equal to the sale price. The foregoing warranty is exclusive and in lieu of all other warranties and representation whether expressed, implied, oral or written, including but not limited to, any implied warranties or merchantability or fitness for a particular purpose. All such other warranties and representations are hereby cancelled

#### NOTICE

The equipment presented in this bulletin is to be installed in accordance with the latest publication standards of NFPA or other similar organisations and also with the provision of government codes or ordinances wherever applicable.

The information provided by us is to the best of our knowledge and belief, and consist of general guidelines only. Site handling and installation control is not in our scope. Hence we give no guarantee for result and take no liability for damages, loss or penalties whatsoever, resulting from our suggestion, information, recommendation or damages due to our product.

Product development is a continuous programme of HD FIRE PROTECT PVT. LTD. and hence the right to modify any specification without prior notice is reserved with the company.



D-6/2, ROAD NO. 34, WAGLE INDUSTRIAL ESTATE, THANE 400 604, INDIA.